

SERVICE LINE REQUIREMENTS

1. Customer shall install and maintain, at his/her own expense, a service line, cutoff valve, and pressure reducing valve which shall begin at the meter and extend to the dwelling and/or place of use. The Customer shall connect his service line to the water and gas distribution system at each respective meter.

2. It is specifically understood by the Customer that the line leaving the meter extending to the dwelling and/or place of use is the sole responsibility of the Customer, which includes, but is not limited to, maintenance and repair. Specifically, any water and/or gas leak in the line after it leaves the meter shall be the sole responsibility of the Customer.

3. A plumbing permit must be obtained from the local health department and must be obtained prior to installation of service to a new waterline with a copy of the same provided to Supplier prior to meter installation. In addition, the following plumbing restrictions apply:

1. The pipe size is to be $\frac{3}{4}$ " inside diameter minimum and shall be 200 PSI.
2. The depth of the pipe must be at a depth a minimum of thirty (30) inches.
3. The location of the waterline must be ten (10) feet away from any sewer line.
4. No direct connection between public drinking water supply and potential source of contamination is permitted. Potential sources of contamination shall be isolated from the public drinking water supply by an appropriate backflow prevention device.
5. No cross-connection between the drinking water supply and a private water system is permitted. These potential threats to the public drinking water supply shall be eliminated at the service connection by the installation of an air-gap or a reduced pressure-zone backflow prevention device.
6. No connection which allows water to be returned to the public drinking water supply is permitted.

